

Arizona Corporation Commission

Docket Control Center

Filings Cover Sheet

ORIGINAL



0000142433

Company/Case Name EAGLETAIL WATER CO LLC

Filing Business As (d/b/a) _____

AZ CORP CASE NO. _____

Docket Number (s) W-03936A-04-0840

DOCKET CODE _____

2013 FEB 19 AM 10 20

Description of Document or Nature of Action
(Please check the item that best describes the nature of the case/filing.)

UTILITIES - NEW APPLICATION

- ☐ New CC&N
- ☐ Rates
- ☐ Interim Rates
- ☐ Cancellation of CC&N
- ☐ Deletion of CC&N
- ☐ Extension of CC&N
- ☐ Tariffs (NEW)
- ☐ Request for Arbitration
- ☐ Full or Partially Arbitrated
- ☐ Interconnection Agreement
- ☐ Voluntary Interconnection Agreement
- ☐ Miscellaneous - Specify: _____

- ☐ Main Extension
- ☐ Contract/Agreements
- ☐ Formal Complaint
- ☐ Waiver/Rule Variance
- ☐ Line Siting Committee Case
- ☐ Small Water Company - Surcharge
- ☐ Sale of Assets & Transfer of Ownership
- ☐ Sale of Assets & Cancellation of CC&N
- ☐ Fuel Adjuster/FER
- ☐ Merger
- ☐ Financing

UTILITIES - REVISIONS/AMENDMENTS TO PENDING OR APPROVED MATTERS

Application: _____

Tariffs: (Procedural or Compliance)
(Check One)

Company: _____

Decision No. 67983

Docket Number: _____

Docket No: W-03936A-04-0840

CURITIES or MISCELLANEOUS FILINGS

- ☐ Affidavit (Publication, Public Notice)
- ☐ Comments
- ☐ Exception
- ☐ Exhibit(s)
- ☐ Notice of Appearance/Intent
- ☐ Notice of Change
- ☐ Opposition
- ☐ Petition

- ☐ Request/Motion for Extension of Time
- ☐ Request/Motion for a Hearing
- ☐ Request/Motion for an Intervention
- ☐ Miscellaneous Request/Motion
- ☐ Request/Motion for a Re-hearing
- ☐ Request/Motion to Compromise Proceedings
- ☐ Request/Motion to Sustain
- ☐ Response
- ☐ Testimony
- ☐ Waiver
- ☐ Witness List

Arizona Corporation Commission
DOCKETED

FEB 19 2013

DOCKETED BY

LM

SUSAN HAAS 928 372236

Please print the name of the person whose signature appears on the filing (i.e. Contact Person, Respondent, Attorney, Applicant, etc.)

EAGLETAIL WATER CO.LLC
P.O. BOX 157
TONOPAH, AZ 85354
928-372-2236

February10, 2013

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix AZ85007

Re: Docket No.W-03936A-04-0840
Decision No.67983

Yearly water loss report for 2012

Enclosed are copies of water loss and water sold in 2012. We have had a very bad year with the main pump not working. We did have very good neighbors providing water for drinking and waste. We did haul water to put in our tank. After the main pump was fixed our pressure pumps went out and we had to purchase new ones. They also fixed many leaks.

Our water lines consist of approximately 30 miles of pipe through rural areas and a leak is not always discovered as quickly as we would like. We will continue to do our best to work for our goal of 10% or less.

Our total gallons pumped for the year is 6045300and the gallons sold are3402409. This shows a water loss of 56.5%. Hopefully we can do much better next year.

If you have any questions regarding this report please call 928-372-2236 or contact us by mail at the address above.

Respectfully,
Eagletail Water Co. LLC

COMPANY NAME: EAGLE TAIL WATER CO LLC

WATER USE DATA SHEET BY MONTH FOR CALENDAR YEAR

MONTH		NUMBER OF CUSTOMERS	GALLONS SOLD	GALLON PUMPED (Thousands)
JANUARY	2012	56	251,680	963000
FEBRUARY	2012	56	207,600	491,000
MARCH	2012	54	219,720	279,000
APRIL	2012	52	336,330	291,000
MAY	2012	52	339,447	43,200
JUNE	2012	49	331,241	513,000
JULY	2012	52	348,880	376,000
AUGUST	2012	52	269,111	362,900
SEPTEMBER	2012	53	220,850	1,368,000
OCTOBER	2012	55	217,620	299,800
NOVEMBER	2012	55	378,550	244,000
DECEMBER	2012	56	251,680	838,200
TOTAL			3402409	6045300

WATER LOSS 56.5%

Is the Water Utility located in an ADWR Active Management Area (AMA)?

() Yes (X) No

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement?

() Yes (X) No

If yes, provide the GPCPD amount: _____

What is the level of arsenic for each well on your system. 5.8 mg/l

(If more than one well, please list each separately.)

Note: If you are filing for more than one system, please provide separate data sheets for each system.